

Kita MP 18

Templari heat pumps full load and variable load performance data with external air temperature as in columns A, B, C and D in compliance with UNI EN 14825 AND UNI EN 14511

| Full load performance - UNI EN 14511 | | | | | | | | |
|--------------------------------------|------------------------|------|------------------------|------|------------------------|------|------------------------|------|
| Water outlet T [°C] | 35 | | 45 | | 55 | | 65 | |
| External T [°C] | Declared capacity [kW] | COP | Declared capacity [kW] | COP | Declared capacity [kW] | COP | Declared capacity [kW] | COP |
| -25 | 7.30 | 1.86 | 7.08 | 1.54 | 6.91 | 1.30 | / | / |
| -20 | 8.63 | 2.20 | 8.40 | 1.82 | 8.18 | 1.54 | 7.96 | 1.29 |
| -15 | 10.05 | 2.55 | 9.79 | 2.11 | 9.53 | 1.79 | 9.24 | 1.50 |
| -10 | 11.57 | 2.91 | 11.26 | 2.42 | 10.94 | 2.04 | 10.56 | 1.71 |
| -7 | 12.54 | 3.16 | 12.19 | 2.61 | 11.83 | 2.20 | 11.38 | 1.83 |
| 2 | 15.93 | 3.99 | 15.40 | 3.22 | 14.81 | 2.73 | 14.10 | 2.23 |
| 7 | 18.05 | 4.61 | 17.38 | 3.72 | 16.68 | 3.10 | 15.79 | 2.54 |
| 12 | 20.37 | 5.35 | 19.55 | 4.26 | 18.72 | 3.53 | 17.67 | 2.88 |

| Part load performance – UNI EN 14825 | | | | |
|--------------------------------------|-------|------|------|-------|
| Correction Factor calculation | A | B | C | D |
| External T [°C] | -7 | 2 | 7 | 12 |
| PLR | 88% | 54% | 35% | 15% |
| Declared capacity [kW] | 12.57 | 7.67 | 4.94 | 4.85 |
| CR | 1.00 | 1.00 | 1.00 | 0.45 |
| COP' (partial load performance) | 3.21 | 4.85 | 7.06 | 11.02 |

$T_{\text{design}} = -10.00^{\circ}\text{C}$
 $\text{SCOP [Average]} = 5.11$

| Chiller mode performance – Fan coil application | | | Chiller mode performance – Cooling floor application | | |
|---|---------------------|-------|--|-------------------|-------|
| Water outlet T 7°C | | | Water outlet T 18°C | | |
| Nominal capacity A35/W7 [kW] | | 12.00 | Nominal capacity A35/W18 [kW] | | 12.00 |
| Part load ratio | Water outlet T [°C] | EER | Part load ratio | Water outlet [°C] | EER |
| 100% | 7.0 | 3.38 | 100% | 18.0 | 5.41 |
| 75% | 8.5 | 4.72 | 75% | 18.0 | 7.66 |
| 50% | 10.0 | 7.62 | 50% | 18.0 | 8.79 |
| 25% | 11.5 | 8.73 | 25% | 18.0 | 10.95 |

$\text{SEER [cooling floor]} = 6.16$
 $\text{SEER [fan coil]} = 5.14$